




**ODISHA FIRE SERVICE  
FIRE SAFETY CERTIFICATE**

**FORM-V**

[Under rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017]



Certificate No:	FIRCER1102080032021000001	Application No:	FSC1102080032020000036
Date of Issue:	09-01-2021	Date of Receipt of Application:	31-12-2020
Valid Up to:	08-01-2023 (midnight)		
(Apply for Renewal of Fire Safety Certificate at least three months before its expiry)			

Certified that the

Laxmi Narayan Public School Sahada  
SabarangDt. Bhadrak  
Odisha PIN-756123

Situated at

Plot No-322/691,323/690, Khata No.-202/54, Street-Sahada, Mouza-  
Dharamsaranbindha, Police Station-Bhadrak rural, District-Bhadrak, Fire Station-  
Bhadrak,

Consisting of total

2 Number of Towers/Blocks, was  
inspected by officers of the Fire Service  
on

09-01-2021

In presence of

Principal and other staffs

Manager  
Laxmi Narayan Public School

Principal  
Laxmi Narayan Public School  
Sahada, Dist-Bhadrak

and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017 read with Odisha Fire Prevention and Fire Safety(Amendment) Rules,2019 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

1. \* Name of the Building(s)/Tower(s)/Block(s):- Laxmi Narayan Public school

\* Floor wise occupancy:-

Sl.No.	Floors in Tower/Block	Usage
1	G Floor-	Class room, offices, principal office & Activity hall
2	1st Floor-	Class room, computer lab, teachers common room, room, Laboratory & Library

2. \* Name of the Building(s)/Tower(s)/Block(s):- Laxmi Narayan Public school


\* Floor wise occupancy:-


Sl.No.	Floors in Tower/Block	Usage
1	G Floor-	Class room, offices, principal office & Activity hall
2	1st Floor-	Class room, computer lab, teachers common room, room, Laboratory & Library

**CONDITIONS:-**

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exits, staircases, corridors and escape way should not be changed, obstructed or modified in any way.
3. The occupiers(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organised at least once in six months by involving Local Fire Station.
5. The occupier(s) shall appoint Fire Safety Supervisor exclusively for this building or premises.
6. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all Towers/Blocks of building/premises.

By order of the Director of Fire Service

  
 Manager  
 Laxmi Narayan Public School

  
 Deputy Fire Officer, Balasore Circle

Laxmi Narayan Public School  
 Sahada Dist-Bhadrak